

CERTIFICATION OF COMPLIANCE

5" SUPER HI-FLO SUCTION: SPC-3 V

Contents: 1

Model Number: **SPC-3 V**

Description: **Super Hi-Flo Suction**

Size: **5"**

Open Area: **9.02 in²**

GPM @ 1.5 fps: **42**

Wall Flow Rate: **232 GPM**
when used with vacuum break fitting

Wall Flow Rate: **180 GPM**
when used without vacuum break fitting



Date of Manufacture:

This product has been tested, certified and listed to the requirements of ASME/ANSI A112.19.8-2007, ASME/ANSI A112.19.8a-2008, ASME/ANSI A112.19.8b-2009 and APSP-16-2011 per §1404 of the Virginia Graham Baker (VGB 2008) Pool and Spa Safety Act. Certified by: Underwriters Laboratories, Inc., 2929 E. Imperial Highway, Suite 100, Brea, CA 92821-6729

This product is certified to comply with §1404 of the Virginia Graham Baker (VGB 2008) Pool and Spa Safety Act. A copy of the test results for the above may be found at www.waterwayplastics.com or go to: www.ul.com. This product is manufactured by Waterway Plastics, Oxnard, CA 93030



2200 East Sturgis Road Oxnard, California 93030 • Ph. 805.981.0262 • Fax 805.981.9403
waterway@waterwayplastics.com • www.waterwayplastics.com