


# CERTIFICATION OF COMPLIANCE

## 18" x 18" GRATES & FRAME

Contents: **1**



Part Number: **640-477X V**

Description: **Grates & Frame**

Size: **18" x 18"**

Open Area: **174.4 in<sup>2</sup>**

GPM @ 1.5 fps: **812**

Floor Flow Rate: **788 GPM**

Wall Flow Rate: **517 GPM**



Date of Manufacture:

Date of Installation: \_\_\_\_\_

Name of Installer: \_\_\_\_\_

Signature of Installer: \_\_\_\_\_

This product has been tested, certified and listed to the requirements of ASME/ANSI A112.19.8-2007, ASME/ANSI A112.19.8a-2008, ASME/ANSI A112.19.8b-2009 and APSP-16-2011 per §1404 of the Virginia Graham Baker (VGB 2008) Pool and Spa Safety Act. Certified by: Underwriters Laboratories, Inc., 2929 E. Imperial Highway, Suite 100, Brea, CA 92821-6729

This product is certified to comply with §1404 of the Virginia Graham Baker (VGB 2008) Pool and Spa Safety Act. A copy of the test results for the above may be found at [www.waterwayplastics.com](http://www.waterwayplastics.com) or go to: [www.ul.com](http://www.ul.com). This product is manufactured by Waterway Plastics, Oxnard CA 93030

*This certificate not valid without signature.*



# Waterway™

2200 East Sturgis Road Oxnard CA 93030 • Phone 805.981.0262 • Fax 805.981.9403  
[waterway@waterwayplastics.com](mailto:waterway@waterwayplastics.com) • [www.waterwayplastics.com](http://www.waterwayplastics.com)